



SOUTH HUNTINGTON

UNION FREE SCHOOL DISTRICT

CREATING THE LEADERS OF TOMORROW

SUPERINTENDENT OF SCHOOLS

David P. Bennardo, Ed.D.

dbennardo@shufsd.org

Phone: 631.812.3070

July 15, 2016

Dear Parent/Guardian:

As the media has so frequently reported, "lead testing," in area water, continues to be a subject of significant interest. To this end, we have endeavored to examine our water supply, intake procedures, and site samples in each building. This initiative is now complete, and we are prepared to share details of our processes and testing.

The water that flows into our South Huntington Schools, which is supplied by a combination of South Huntington, Greenlawn, and Huntington Authorities, has been found to be without source contamination. The specific building pipes that then pump water into our primary, intermediate, middle, and high school buildings, were all replaced as part of our previous Capital Bond Project. Therefore, any lead pipes were switched with plastic or copper, and are without lead composition or contamination. Additionally, the water at specific entrance sites in the buildings, which has been regularly tested for bacteria, is now being screened for lead by H2M Architects and Engineers, who are industry leaders in this area.

At our request, water samples were collected in accordance with the EPA's latest (October, 2006) guidance manual "3Ts for Reducing Lead in Drinking Water in School" over a two-week period. The tests which included all water drinking locations, food preparation sinks, classroom bubblers, faculty lounges, and nurse's office sinks, were conducted in multiple buildings, per day, over a two-week period. In total, over 300 water input locations were tested using a first and second draw sample. This means that a faucet or fountain is tested first after 6-8 hours of inactivity, and then again about 30 seconds later. The idea behind this method is that an older fixture might build up a small lead reading after a period of inactivity, which is then flushed after the first draw of the morning.

Our test results indicate that of the 308 locations sampled, 292 were under the recommended 20 ppb on the first draw sample, and the remaining 16 came under the required threshold on the second draw sample, which occurred thirty seconds later. While the H2M recommendation does allow us the option of instituting a morning flushing system each day, we have elected instead to replace a total of 16 fixtures in the following areas.

Countrywood Main Office Sink (1)

Countrywood, Room 317 Sink and Bubbler Fountain (1)

Maplewood, Room 204 Sink and Bubbler Fountain (2)

Silas Wood, Room 227 Sink and Bubbler Fountain (1)

Stimson Home & Career, Rooms 217 and 218 Sinks (7)

Memorial – Boys Bathroom Area Fountain, as well as 2 Girl's Locker Room Fountains (3)

Memorial – Faculty Room sink (1)


Note: All replacement fixtures are NSF/ANSI61 Approved Lead Free

These replacements are already underway, and it is our expectation that all 16 new fixtures will be in place before the start of the new school year. Furthermore, we will not have students or staff from our summer programs using any of the fixtures that are scheduled for replacement.

Finally, we will be instituting a series of periodic testing as part of our typical yearly processes to ensure continued water quality for our school community.

You can view the full H2M report on our website at www.shufsd.org.

Sincerely,


David P. Bennardo, Ed.D.
Superintendent of Schools



architects + engineers

538 Broad Hollow Road, 4th Floor East
Melville, NY 11747

tel 631.756.8000
fax 631.694.4122

September 30, 2016

Ms. Geralynn Rosser
Associate Hydrologist
Suffolk County Department of Health Services
3500 Sunrise Highway, #124
Great River, NY 11739

**RE: Drinking Water Lead Testing Results
South Huntington Union Free School District
Initial Compliance Letter**

Dear Ms. Rosser:

In accordance with the guidelines outlined within the recently enacted legislation 10 NYCRR 67-4: Lead Testing in School Drinking Water, School Districts are required to test potable water for lead contamination and to implement a lead remediation plan. As part of the regulations each District is required to notify their local health department with the results of their first draw samples. H2M architects + engineers have been retained by the South Huntington U.F. School District to assist them in meeting these requirements and on their behalf, the following represents their actions to date.

H2M along with the District administration developed an action plan and identified all cold water outlets which are currently or potentially used for drinking or cooking within each of their three buildings, they include the following: drinking fountains, kitchen sinks, classroom drinking fountains at combination sinks, Teacher's lounge, nurse's office sinks and other special visible sinks or fixtures readily available for consumptions such as outlets used for filling coffee urns. As a result, a total of 308 first draw samples were taken (see attached chart for location, result and dates sample was taken).

All samples taken followed both the EPA's sampling protocol and Subpart 67-4, each sample volume collected was 250 mL following a minimum of 8 hours of non-use, but not more than 18 hours. All first draw samples were analyzed by a laboratory approved to perform such analyses by the NYS Health Departments Environmental Laboratory Approved Program (ELAP). The action levels of lead concentration which require a response are 15 micrograms per liter (μL) or parts per billion (ppb).

The District has implemented an action plan for those outlets that exceed the 15ppb which includes replacement of the bubblers and faucets or taking off-line fixture that are not essential to the operation of the building. They are currently in the process of completing this work and will resample those outlets upon completion of the corrective work. Please note the District intends to temporarily close any fixture until the work can be completed. The District also understands that there may be additional outlets that need to be sampled such as sinks within student toilets, concession stand food prep sinks, supply lines to ice machines and exterior hose bibs used by athletic teams and is awaiting further direction from the NYDOH. Once clarification and additional guidance is given the District will follow the same protocol and action plan described herein.



If you have any questions or require additional information, please feel free to contact me at (631) 393-4922.

Very truly yours,
H2M architects + engineers

A handwritten signature in black ink, appearing to read 'Saverio J. Belfiore', written over the text 'H2M architects + engineers'.

Saverio J. Belfiore, AIA, CSI, CDT
Vice President | Studio Director

SJB/pld

Encl: (9)

cc:

H2M_File, PLD

SHSD_K.Kenedy – Plant Facilities Administrator

SHSD_Dr. Bennardo – Superintendent of Schools

SHSD_J. Centamore – District Administration Office

X:\SHSD (South Huntington School District) - 10884\SHSD1603_Water Testing\13_RPT - Report - Studies\SCHD letter\SCHD letter.doc

Drinking Water Lead Sampling Results

For: South Huntington Union Free School District



Birchwood School	39 samples	
Location of sample	Date of Sample	First Draw Sample Results (ppb)
Wall H-Fountain	May 20, 2016	1.720
N Office Sink	May 20, 2016	1.260
F Sink	May 20, 2016	5.810
Girls Locker Room Drinking Fountain	May 20, 2016	0.754
Boys Locker Room Drinking Fountain	May 20, 2016	3.280
Kitchen Sink	May 20, 2016	4.080
Class Room 101 Sink	May 20, 2016	1.480
Class Room 102 Sink	May 20, 2016	2.120
Class Room 104 Sink	May 20, 2016	16.500
Class Room 105 Sink	May 20, 2016	1.430
Class Room 106 Sink	May 20, 2016	1.870
Class Room 107 Sink	May 20, 2016	1.960
Class Room 108 Sink	May 20, 2016	1.820
Class Room 113 Sink	May 20, 2016	3.110
Class Room 114 Sink	May 20, 2016	7.280
Class Room 115 Sink	May 20, 2016	3.100
Class Room 116 Sink	May 20, 2016	7.020
Class Room 117 Sink	May 20, 2016	2.040
Class Room 118 Sink	May 20, 2016	2.370
Class Room 119 A Sink	May 20, 2016	1.910
Class Room 120 A Sink	May 20, 2016	3.400
Class Room 121 A Sink	May 20, 2016	2.270
Class Room 124 A Sink	May 20, 2016	1.490
Class Room 126 A Sink	May 20, 2016	1.980
Drinking Fountain 2nd Floor Hall Boys	May 20, 2016	8.960
Drinking Fountain 2nd Floor Hall Girls	May 20, 2016	10.800
Class Room 200 A Sink	May 20, 2016	5.150
Class Room 201 A Sink	May 20, 2016	2.350
Class Room 202 A Sink	May 20, 2016	1.410
Class Room 203 A Sink	May 20, 2016	1.610
Class Room 204 A Sink	May 20, 2016	2.100
Class Room 205 A Sink	May 20, 2016	1.500
Class Room 206 A Sink	May 20, 2016	1.930
Class Room 207 A Sink	May 20, 2016	1.950
Class Room 208 A Sink	May 20, 2016	1.320
Class Room 209 A Sink	May 20, 2016	1.520
Class Room 210 A Sink	May 20, 2016	2.710
Class Room 211 A Sink	May 20, 2016	1.310
Class Room 212 A Sink	May 20, 2016	1.480

Countrywood School		44 samples
Location of sample	Date of Sample	First Draw Sample Results (ppb)
Class Room 502 Sink	May 19, 2016	5.640
Nurses Office	May 19, 2016	7.740
Nurses Office Toilet Room	May 19, 2016	2.910
Office Drinking Fountain	May 19, 2016	0.922
Office Sink	May 19, 2016	31.700
Office Bath	May 19, 2016	6.600
Lobby Drinking Fountain	May 19, 2016	1.030
Class Room 101 Sink	May 19, 2016	3.720
Class Room 100 Sink	May 19, 2016	6.200
Class Room 102 Sink	May 19, 2016	4.760
Class Room 103 Sink	May 19, 2016	12.200
Class Room 105 Sink	May 19, 2016	12.200
Class Room 104 Sink	May 19, 2016	2.410
Class Room 107 Sink	May 19, 2016	6.500
Class Room 106 Sink	May 19, 2016	6.690
Class Room 109 Sink	May 19, 2016	11.900
Class Room 108 Sink	May 19, 2016	8.840
Class Room 110 Sink	May 19, 2016	8.520
Class Room 111 Sink	May 19, 2016	8.320
Kitchen Sink 1	May 19, 2016	2.090
Kitchen Sink 2	May 19, 2016	0.424
200 Wing Drinking Fountain	May 19, 2016	1.010
Class Room 200 Sink	May 19, 2016	7.090
Class Room 202 Sink	May 19, 2016	1.480
Class Room 203 Sink	May 19, 2016	2.220
Class Room 205 C Sink	May 19, 2016	6.860
Class Room 317 Sink	May 19, 2016	26.700
Class Room 509 Sink	May 19, 2016	10.800
Class Room 507 Sink	May 19, 2016	7.340
Class Room 505 Sink	May 19, 2016	8.870
Class Room 503 Sink	May 19, 2016	5.850
Class Room 501 Sink	May 19, 2016	12.100
Class Room 315 Sink	May 19, 2016	6.430
Class Room 313 Sink	May 19, 2016	17.800
Class Room 302 Sink	May 19, 2016	0.499
Class Room 311 A Sink	May 23, 2016	6.230
Class Room 309 A Sink	May 23, 2016	13.100
Class Room 303 A Sink	May 23, 2016	5.440
Class Room 300A Sink	May 23, 2016	2.870
Class Room 301 A Sink	May 23, 2016	3.260
Class Room 300 AA Sink	May 23, 2016	9.390
300 Wing Drinking Fountain	May 23, 2016	0.435
Gymnasium	May 23, 2016	4.270
Class Room 101C Sink	May 23, 2016	7.530

Maplewood Elementary School		46 samples
Location of sample	Date of Sample	First Draw Sample Results (ppb)
Class Room 109 Sink	May 23, 2016	1.170
Class Room 107 Sink	May 23, 2016	1.270
Class Room 108 Sink	May 23, 2016	1.150
Class Room 105 Sink	May 23, 2016	1.330
Class Room 106 Sink	May 23, 2016	0.593
Class Room 104 Sink	May 23, 2016	1.730
Class Room 102 Sink	May 23, 2016	2.230
Class Room 101 Sink	May 23, 2016	7.680
Class Room 100 Sink	May 23, 2016	1.950
Class Room 200 Sink	May 23, 2016	4.620
Class Room 201 Sink	May 23, 2016	1.760
Class Room 202 Sink	May 23, 2016	1.340
Class Room 204 Sink	May 23, 2016	20.500
Class Room 203 Sink	May 23, 2016	4.660
Class Room 205 Sink	May 23, 2016	0.627
Class Room 206 Sink	May 23, 2016	0.738
Class Room 207 Sink	May 23, 2016	1.030
Class Room 208 Sink	May 23, 2016	1.760
Class Room 209 Sink	May 23, 2016	1.110
Class Room 211 Sink	May 23, 2016	1.310
Class Room 210 Sink	May 23, 2016	1.160
Class Room 212 Sink	May 23, 2016	0.458
200 BR Girls	May 23, 2016	2.220
200 BR Boys	May 23, 2016	1.030
Kitchen	May 23, 2016	0.208
100 BR Girls	May 23, 2016	0.634
100 BR Boys	May 23, 2016	0.444
Outside Cafe	May 23, 2016	0.297
Gymnasium Boys	May 23, 2016	0.732
Gymnasium Girls	May 23, 2016	2.180
Nurse Office	May 23, 2016	0.195
Nurse BR	May 23, 2016	0.536
Class Room 123 Sink	May 23, 2016	6.070
Class Room 124 Sink	May 23, 2016	2.000
Class Room 122 Sink	May 23, 2016	2.150
Class Room 121 Sink	May 23, 2016	1.420
Class Room 120 Sink 1	May 23, 2016	2.730
Class Room 120 Sink 2	May 23, 2016	3.570
Class Room 119 Sink 1	May 23, 2016	3.590
Class Room 119 Sink 2	May 23, 2016	7.090
Class Room 117 Sink	May 23, 2016	9.650
Class Room 115 Sink	May 23, 2016	2.770

Class Room 116 Sink	May 23, 2016	1.360
Class Room 113 Sink	May 23, 2016	2.150
Class Room 114 Sink	May 23, 2016	1.050
Class Room 111 Sink	May 23, 2016	1.920

Memorial Junior High School		22 samples
Location of sample	Date of Sample	First Draw Sample Results (ppb)
Outside Class Room 304	May 25, 2016	<1.000
Outside Class Room 301	May 25, 2016	2.600
Gymnasium 1	May 25, 2016	2.800
Gymnasium 2	May 25, 2016	3.100
W. Café	May 25, 2016	<1.000
Class Room 413 Sink	May 25, 2016	2.600
Boys Lockers	May 25, 2016	5.000
Outside Girls	May 25, 2016	13.000
Outside Boys	May 25, 2016	26.000
Girls Lockers	May 25, 2016	64.000
Girls Lockers 2	May 25, 2016	31.000
Kitchen 1	June 4, 2016	6.800
Kitchen 2	June 4, 2016	<1.000
Near Kitchen	June 4, 2016	5.400
Cafeteria	June 4, 2016	2.700
Class Room 101 Sink	June 4, 2016	1.400
Near Class Room 108	June 4, 2016	1.600
Faculty Room	June 4, 2016	33.000
Near Class Room 201	June 4, 2016	6.800
Near Class Room 204	June 4, 2016	1.100
Nurses Office	June 4, 2016	18.000
Kitchen	June 7, 2016	<1.000

Oakwood School		45 samples
Location of sample	Date of Sample	First Draw Sample Results (ppb)
Class Room 111 Sink	May 20, 2016	17.900
Class Room 110 Sink	May 20, 2016	3.880
Class Room 108 Sink	May 20, 2016	8.750
Class Room 106 Sink	May 20, 2016	3.750
Class Room 104 Sink	May 20, 2016	3.440
Class Room 107 Sink	May 20, 2016	8.230
Class Room 109 Sink	May 20, 2016	12.200
Class Room 102 Sink	May 20, 2016	6.100
Class Room 101 Sink	May 20, 2016	4.110
BR 100 Girls	May 20, 2016	1.840
BR 100 Boys	May 20, 2016	5.060
Cafeteria	May 20, 2016	0.215
Kitchen	May 20, 2016	10.800
Outside Café	May 20, 2016	0.144
Gym	May 20, 2016	0.768
Nurses Office	May 20, 2016	0.868
Nurse BR	May 20, 2016	0.948
Class Room 117B Sink	May 20, 2016	13.700
Class Room 119 Sink	May 20, 2016	2.620
Class Room 118 Sink	May 20, 2016	2.350
Class Room 121 Sink	May 20, 2016	3.080
Class Room 123 Sink	May 20, 2016	3.390
Class Room 120 Sink	May 20, 2016	2.840
Faculty	May 20, 2016	0.532
Class Room 116 Sink	May 20, 2016	7.070
Class Room 115 Sink	May 20, 2016	1.360
Class Room 114 Sink	May 20, 2016	2.600
Class Room 112 Sink 1	May 20, 2016	3.150
Class Room 112 Sink 2	May 20, 2016	5.230
Class Room 113 Sink	May 20, 2016	4.960
BR 200 Girls	May 20, 2016	5.630
BR 200 Boys	May 20, 2016	7.070
Class Room 202 Sink	May 20, 2016	8.570
Class Room 204 Sink	May 20, 2016	15.100
Class Room 201 Sink	May 20, 2016	3.270
Class Room 206 Sink	May 20, 2016	2.410
Class Room 203 Sink	May 20, 2016	2.870
Class Room 205 Sink	May 20, 2016	1.430
Class Room 207 Sink	May 20, 2016	4.730
Class Room 209 Sink	May 20, 2016	4.850
Class Room 211 Sink	May 20, 2016	1.710
Class Room 214 Sink	May 20, 2016	14.400

Class Room 212 Sink	May 20, 2016	7.390
Class Room 210 Sink	May 20, 2016	11.100
Class Room 208 Sink	May 20, 2016	8.910

Silaswood Elementary School		32 samples
Location of sample	Date of Sample	First Draw Sample Results (ppb)
Kitchen Sink 1	June 4, 2016	1.200
Kitchen Sink 2	June 4, 2016	2.100
Kitchen Sink 5	June 4, 2016	3.700
Kitchen Sink 3	May 23, 2016	12.600
Kitchen Sink 4	May 23, 2016	0.422
Kitchen Sink 6	May 23, 2016	6.300
Class Room 113 Sink	May 23, 2016	1.500
Class Room 111 Sink	May 23, 2016	4.310
Drinking Fountain by Class Room 112	May 23, 2016	2.140
Gymnasium 1	May 23, 2016	0.565
Gymnasium 2	May 23, 2016	0.348
Nurses Office	May 23, 2016	7.670
Drinking Fountain by Class Room 001	May 23, 2016	0.044
Class Room 106 Sink	May 23, 2016	1.890
Class Room 101 Sink	May 23, 2016	1.380
Class Room 102 Sink	May 23, 2016	4.520
Class Room 122 Sink	May 23, 2016	4.920
Class Room 124 Sink	May 23, 2016	8.190
Class Room 127 Sink	May 23, 2016	14.100
Class Room 128 Sink	May 23, 2016	0.600
Class Room 215 Sink	May 23, 2016	0.302
Drinking Fountain by Class Room 212	May 23, 2016	1.060
Teachers Room 2nd Floor	May 23, 2016	0.226
Drinking Fountain by Class Room 203	May 23, 2016	0.199
Class Room 203 Sink	May 23, 2016	1.550
Drinking Fountain by Class Room 220	May 23, 2016	0.569
Class Room 220 Sink	May 23, 2016	5.920
Class Room 222 Sink	May 23, 2016	1.230
Class Room 224 Sink	May 23, 2016	4.730
Class Room 227 Sink	May 23, 2016	50.600
Class Room 228 Sink	May 23, 2016	1.610
Bus Trans Fountain	May 23, 2016	3.860

Stimson Middle School		41 samples
Location of sample	Date of Sample	First Draw Sample Results (ppb)
Custodial	June 3, 2016	9.700
Near Custodial	June 3, 2016	<1.000
Kitchen Sink 1	June 3, 2016	3.200
Kitchen Sink 2	June 3, 2016	2.200
Kitchen Sink 3	June 3, 2016	14.000
Kitchen Sink 4	June 3, 2016	3.100
Kitchen Sink 5	June 3, 2016	14.000
Drinking Fountain Outside	June 3, 2016	2.300
Drinking Fountain Near Exit 5	June 3, 2016	<1.000
Main Office Drinking Fountain	June 3, 2016	<1.000
Class Room 607 Sink	June 3, 2016	1.100
Health Office Sink 1	June 3, 2016	2.200
Health Office Sink 2	June 3, 2016	<1.000
Drinking Fountain by Girls Gym B	June 3, 2016	<1.000
Drinking Fountain by Boys Gym B	June 3, 2016	4.400
Drinking Fountain by Room 521	June 3, 2016	3.200
Class Room 317 Sink	June 3, 2016	4.600
Drinking Fountain Near Class Room 303	June 3, 2016	<1.000
Drinking Fountain Near Class Room 306	June 3, 2016	<1.000
Drinking Fountain Near Class Room 310	June 3, 2016	1.100
Drinking Fountain Near Class Room 212	June 3, 2016	3.400
Drinking Fountain Near Class Room 210 W	June 3, 2016	<1.000
Drinking Fountain Near Class Room 210 E	June 3, 2016	1.100
Class Room 049 Sink	June 3, 2016	8.200
Drinking Fountain Near Class Room 221 W	June 3, 2016	<1.000
Drinking Fountain Near Class Room 221 E	June 3, 2016	1.000
Class Room 218 Sink 1	June 3, 2016	28.000
Class Room 218 Sink 2	June 3, 2016	24.000
Class Room 218 Sink 3	June 3, 2016	21.000
Class Room 218 Sink 4	June 3, 2016	30.000
Class Room 217 Sink 1	June 3, 2016	18.000
Class Room 217 Sink 2	June 3, 2016	22.000
Class Room 217 Sink 3	June 3, 2016	31.000
Class Room 217 Sink 4	June 3, 2016	63.000
Class Room 097 Sink	June 3, 2016	1.000
Drinking Fountain Near Class Room 107	June 3, 2016	3.200
Drinking Fountain Near Class Room 412	June 4, 2016	2.400
Library Sink	June 4, 2016	6.700
Drinking Fountain Near Class Room 411	June 4, 2016	<1.000
Drinking Fountain Near Class Room 405	June 4, 2016	<1.000
Drinking Fountain Near Class Room 403	June 4, 2016	<1.000

Walt Whitman High School		34 samples
Location of sample	Date of Sample	First Draw Sample Results (ppb)
South Nurses Office	June 4, 2016	<1.000
South Nurse BR	June 4, 2016	2.400
Boys Locker Room 1	June 4, 2016	<1.000
Boys Locker Room 2	June 4, 2016	<1.000
Outside Class Room 214 Drinking Fountain	June 4, 2016	<1.000
Outside Class Room 204 Drinking Fountain 1	June 4, 2016	1.800
Outside Class Room 204 Drinking Fountain 2	June 4, 2016	1.900
Outside Class Room 104 Drinking Fountain 1	June 4, 2016	<1.000
Outside Class Room 104 Drinking Fountain 2	June 4, 2016	1.900
Outside Class Room 113 Drinking Fountain 1	June 4, 2016	<1.000
Outside Class Room 113 Drinking Fountain 2	June 4, 2016	<1.000
Outside Class Room 302 Drinking Fountain 1	June 4, 2016	2.200
Outside Class Room 302 Drinking Fountain 2	June 4, 2016	5.000
Outside Class Room 312 Drinking Fountain 1	June 4, 2016	<1.000
Outside Class Room 312 Drinking Fountain 2	June 4, 2016	<1.000
Outside Café	June 4, 2016	<1.000
Cafeteria	June 4, 2016	<1.000
Kitchen 1	June 4, 2016	3.300
Gymnasium 1	June 4, 2016	4.800
Gymnasium 2	June 4, 2016	1.300
Gymnasium 3	June 4, 2016	1.300
Outside Class Room 224 Drinking Fountain 1	June 4, 2016	<1.000
Outside Class Room 224 Drinking Fountain 2	June 4, 2016	<1.000
Outside Class Room 227 Drinking Fountain 1	June 4, 2016	<1.000
Outside Class Room 227 Drinking Fountain 2	June 4, 2016	<1.000
Outside Class Room 528 Drinking Fountain	June 4, 2016	<1.000
Main Office	June 4, 2016	<1.000
Main Office Sink	June 4, 2016	2.500
Outside Class Room 631 Drinking Fountain 1	June 4, 2016	1.200
Outside Class Room 617 Drinking Fountain 1	June 4, 2016	2.800
Outside Class Room 617 Drinking Fountain 2	June 4, 2016	1.200
Outside Class Room 616 Drinking Fountain 1	June 4, 2016	1.600
Outside Class Room 616 Drinking Fountain 2	June 4, 2016	2.300
Outside Class Room 614 Drinking Fountain	June 4, 2016	4.600

District Office		3 samples
Location of sample	Date of Sample	First Draw Sample Results (ppb)
Nurses Office Outside 200 Drinking Fountain Kitchen	June 7, 2016	14.000
	June 7, 2016	6.000
	June 7, 2016	15.000

Old Library		1 sample
Location of sample	Date of Sample	First Draw Sample Results (ppb)
Outside BR	June 7, 2016	<1.000

Teen Center		1 sample
Location of sample	Date of Sample	First Draw Sample Results (ppb)
Drinking Fountain	June 4, 2016	<1.000

